

Declaration of Conformity

CE MARKING

Power-One Italy S.p.a.
Via San Giorgio, 642 - 52028 Terranuova B.ni (AR) - Italy

declares, under its own responsibility, that the following product

Product: Photo-Voltaic Inverter
Trade Mark: Power-One
Type: Aurora Series
Models: PVI-CENTRAL-X-TL-FR
where X = 50, 100, 150, 200, 250 or 300

to which this declaration relates, is in compliance with the essential requirements of the following European Directives:

2006/95/EC

Directive of the European Parliament and of the Council of 12 December 2006 on the harmonization of the laws of Member States relating to electrical equipment designed for use within certain voltage limits.

Conformity was proved by the application of the following standard:

EN 50178: 1997

2004/108/EC

Directive of the European Parliament and of the Council of 15 December 2004 on the approximation of the laws of the Member States relating to electromagnetic compatibility and repealing Directive 89/336/EEC.

Conformity was proved by the application of the following standards:

EN 61000-6-2: 2001

EN 61000-6-4: 2001

EN 61000-3-12: 2005

EN 61000-3-11: 2000

The products are furthermore in compliance with the “ Richtlinie für den Anschluss und Parallelbetrieb von Eigenerzeugungsanlagen am Mittelspannungsnetz “ (Regulation for the connection and parallel operation of power generation units with the medium voltage utility), 4th Issue, Version 2002 of the VDEW.

The subject products are developed and manufactured in an UNI EN ISO 9001 certified factory and are 100% tested on functioning and safety during manufacturing.

. / .




PVI-CENTRAL-50-TL-FR & others (ce declaration)

Based on the above, the product is eligible to be **CE** marked.

Note this Declaration of Conformity is not valid any longer, in case, without any written authorization by Power-One Italy S.p.a.:

- the product is modified, supplemented or changed in any other way ;
- components, which are not part of the accessories kit, if any, are integrated in the product ;
- the product is used or installed improperly.


(Manufacturer)

Ing. Alessandro Falciani
Quality Assurance Manager

Terranuova Bracciolini
(Place)

2009 / 04 / 08
(Date)